IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

doing to correct this situation. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are We routinely monitor for the presence of drinking water contaminants. Our water system recently violated drinking water standards.

past 12 months. The level of total trihalomethanes averaged at our system's locations was 0.082, 0.087, 0.083, 0.088 and 0.087 (MCl) for total trihalomethanes is 0.080 mgll. It is determined by averaging all the samples collected at each sampling location for the Testing results we received for April 2015 through March 2016, July 2015 through June 2016, and October 2015 through September 2016 show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes. The standard or Nowata Municipal Authority Has Levels o(Total Trihalomethanes (TTHMs) Above Drinking Water Standards

elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are

or central nervous system, and may have an increased risk of getting cancer who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, What does this mean? This is not an emergency. If it had been, you would have been notified immediately. However, some people

Corrective Action

The City's Water Treatment Plant operators are making adjustments to the treatment process and flushing hydrants to lower the TTHM levels. The City will continue to sample and monitor the levels of disinfection bi-products.

For further information contact: City Hall at 114 South Maple Street Nowata OK, 74048 or call 918-273-3538

directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a Please share this information with all the other people who drink this water, especially those who may not have received this notice public place or distributing copies by hand or mail.

This notice is being sent to you by the Nowata Municipal Authority PWSID#: OKI021503 Date Distributed: NOV #: P-J021503-17-1